


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-246565e-14-Ho
Ansprechpartnerin: Dipl.-Ing. (FH) S. Horn

Certificate

Hygiene – conformity check

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: HVAC system „Qubic“

Manufacturer: Samp S.p.A.
Via E. Vittorini, 9
20049 Concorezzo (MI)
ITALY

Basis of the examination: ✓ VDI 6022, Blatt 1 (07/2011)

Validity period: 5 years 04/2015 – 04/2020

Test report: W-246565e-14-Ho



In conclusion it can be stated that the examined HVAC system „Qubic“, as specified in the test report W-246565e-14-Ho, is in compliance with the above mentioned regulation.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)
Section head of Air Conditioning technology
Department of Water Hygiene and
Environmental Microbiology

issued 27.04.2015, Gelsenkirchen

Within the framework of the hygiene conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt.-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)